



BRISBANE | SYDNEY | CANBERRA

Indesign Building Pty t/a Indesign Access

Post: u18 – 14 Astan Place Banyo, 4014

Head Office: 0410 559 196

Email: admin@indesignaccess.com.au

Web: www.indesignaccess.com.au

ABN: 417 1277 2070

To whom it my concern.

C/o Geberit Pty Ltd

RE: Compliance Acknowledgment

In-Wall Flush Systems Sigma Range.

Acknowledge;

Assessment has been performed by this office, with reference to the 'Sigma Range' as out-lined within Description of component/s.

Subject to the suitability for Person With Disabilities (PWD) and the performance requirements outlined within Building Code of Australia (BCA) Clause F2.4, Table 2.4 (a)&(b), Disability (Access to Premises - Buildings) Standards 2010, Australian Standard AS1428.1-2009 (incorporating Amendment No.1) and subordinate legislation.

Building/Structure description;

BCA V1 Class 2-9 Structures – Public Spaces

BCA V2 Class 1 Structures – Specialist Disability Accommodation (SDA) & National disability Insurance Scheme (NDIS).

Description of component/s;

Assessment of the Sigma80, Sigma70, Sigma50, Sigma21, Sigma20 & Sigma Square Remote Pivot Plate (Type 70) flush mechanisms, operating with the approved Geberit Sigma8 Concealed Cistern.

Certification;

Our assessment of the documentation and suitability of the nominated Geberit Flush Activation Mechanisms, coupled with the Sigma8 Concealed Cisterns was overlaid with permissible zone, indicated in Clause 15 of the AS1428.1-2009 Design for access and mobility Part 1: General requirements for access—New building work as that complies with the heights above Finish Floor Levels (FFL) and centreline of pan'.

Not limited to' the use for residential accommodation suiting personal clinical needs of a PWD within the home environment and compliant for the use within Livable Housing Design guidelines (LHA) and SDA.

In support of this information received, I am satisfied the range assessed meets building code compliance and suitable the broader requirements for PWD i.e. home modifications.

Regards

Director



Rhys Tappenden

Accredited Member- Association of Consultants in Access Australia (ACAA),# 428

Building Designer – QBCC - Lic#1168941. | Builder open – QBCC – Lic#1168941. | Livable Design Guidelines Qualified & Registered Assessor #10023. | Technical Advisor & Appointed Panel member (TAP) - Livable Housing Design.